


Environmental product declaration

in accordance with ISO 14025 and EN 15804+A2

EASY STRIP 5G2,5 T500



Disclaimer: image may not be identical to product declared, but represents the product family.



The Norwegian EPD Foundation

Owner of the declaration:

Prysmian Group Danmark A/S

Product:

EASY STRIP 5G2,5 T500

Declared unit:

1 m

This declaration is based on Product Category Rules:

CEN Standard EN 15804:2012+A2:2019 serves as core PCR

NPCR 027:2020 Part B for Electrical cables and wires

Program operator:

The Norwegian EPD Foundation

Declaration number:

NEPD-8350-8031-EN

Registration number:

NEPD-8350-8031-EN

Issue date: 06.12.2024

Valid to: 06.12.2029

EPD software:

LCAno EPD generator ID: 630551

General information

Product

EASY STRIP 5G2,5 T500

Program operator:

The Norwegian EPD Foundation
Post Box 5250 Majorstuen, 0303 Oslo, Norway
Phone: +47 977 22 020
web: www.epd-norge.no

Declaration number:

NEPD-8350-8031-EN

This declaration is based on Product Category Rules:

CEN Standard EN 15804:2012+A2:2019 serves as core PCR
NPCR 027:2020 Part B for Electrical cables and wires

Statement of liability:

The owner of the declaration shall be liable for the underlying information and evidence. EPD Norway shall not be liable with respect to manufacturer information, life cycle assessment data and evidences.

Declared unit:

1 m EASY STRIP 5G2,5 T500

Declared unit with option:

A1,A2,A3,A4,A5,B1,B2,B3,B4,B5,B6,B7,C1,C2,C3,C4,D

Functional unit:

1 m of installed EASY STRIP 5G2,5 300/500 V Halogen-free, fire retardant and UV-stabilized cable, used to transmit a reference electric current of 1A at use rate 70% over a period of 30 years, including waste treatment at end-of-life.

General information on verification of EPD from EPD tools:

Independent verification of data, other environmental information and the declaration according to ISO 14025:2010, § 8.1.3 and § 8.1.4. Verification of each EPD is made according to EPD-Norway's guidelines for verification and approval requiring that tools are i) integrated into the company's environmental management system, ii) the procedures for use of the EPD tool are approved by EPD-Norway, and iii) the process is reviewed annually by an independent third party verifier. See Appendix G of EPD-Norway's General Programme Instructions for further information on EPD tools

Verification of EPD tool:

Independent third party verification of the EPD tool, background data and test-EPD in accordance with EPDNorway's procedures and guidelines for verification and approval of EPD tools. Approval number: NEPDT32.

Third party verifier:

Vito D'Incognito, Take Care International

(no signature required)

Owner of the declaration:

Prysmian Group Danmark A/S
Contact person: Gustaf Jonsson
Phone: +45 60 39 26 29
e-mail: gustafjonsson@prysmian.com

Manufacturer:

Prysmian Group Danmark A/S
Roskildevej 22
2620 Albertslund, Denmark

Place of production:

Prysmian Group production site Keila (Baltics)
Paldiski maantee 31
76606 Keila, Estonia

Management system:

ISO 9001, ISO 14001, ISO 45001

Organisation no:

DK27917887

Issue date:

06.12.2024

Valid to:

06.12.2029

Year of study:

2023

Comparability:

EPD of construction products may not be comparable if they not comply with EN 15804 and seen in a building context.


Development and verification of EPD:

The declaration is created using EPD tool lca.tools ver EPD2022.03, developed by LCA.no. The EPD tool is integrated in the company's management system, and has been approved by EPD Norway. Approval number: NEPDT33

Developer of EPD: Siri Andersen

Reviewer of company-specific input data and EPD: Anders Nymark

Approved:



Håkon Hauan
Managing Director of EPD-Norway

Product

Product description:

Halogen-free, fire retardant and UV-stabilized cable for fixed installation indoors in walls, trays, ducts or outdoors in pipes, air or directly in the ground. Not suitable for application in vibrated concrete.

Easy Strip is listed in Ecolabel database and suitable for Svanemærket certified buildings.

Product specification

Cable Shape: Round

Conductors: solid annealed copper wires

Conductor Insulation: XLPE

Filler: Halogen free compound

Outer Sheath: Halogen free compound, UV resistant.

Nominal voltage: U0 300V

Nominal voltage: U 500V

| Materials | kg | % |
|--------------------------------|------|--------|
| HFFR Polyolefin | 0,03 | 16,90 |
| Kraft paper - Bleached | 0,00 | 0,60 |
| Metal - Copper | 0,11 | 52,84 |
| Plastic - Polyethylene | 0,02 | 8,65 |
| Textile - Cotton | 0,00 | 0,67 |
| Thermoplastic elastomers (TPE) | 0,04 | 20,34 |
| Total | 0,20 | 100,00 |

| Packaging | kg | % |
|---------------------------|------|--------|
| Packaging - Plastic drums | 0,02 | 100,00 |
| Total incl. packaging | 0,22 | 100,00 |

Technical data:

Adheres to:

EN 50363 Design standard

EN 60228 Conductor standard

EN 50575:2014 Cables for general applications in construction works subject to reaction to fire requirements

EN 50267-1 Halogen free material

EN 50267-2-3 Corrosive gases

EN 61034-1-2

REACH Regulation concerning the Registration, Evaluation, Authorization and Restriction of Chemicals.

ROHS RoHS compliance - restriction of hazardous substances directive

Market:

Denmark

Reference service life, product

30 years. Standard lifetime for residential/tertiary/industrial building applications, provided in appendix 1 of PSR for wires, cables, and accessories of PEP Ecompassport.

Reference service life, building or construction works

30 years. Estimation made to match the product service life and keep the EPD environmental impact calculations at the product level.

LCA: Calculation rules

Declared unit:

1 m EASY STRIP 5G2,5 T500

Cut-off criteria:

All major raw materials and all the essential energy is included. The production processes for raw materials and energy flows with very small amounts (less than 1%) are not included. These cut-off criteria do not apply for hazardous materials and substances.

Allocation:

The allocation is made in accordance with the provisions of EN 15804. Incoming energy and water and waste production in-house is allocated equally among all products through mass allocation. Effects of primary production of recycled materials is allocated to the main product in which the material was used. The recycling process and transportation of the material is allocated to this analysis.

Data quality:

Specific data for the product composition are provided by the manufacturer. The data represent the production of the declared product and were collected for EPD development in the year of study. Background data is based on EPDs according to EN 15804 and different LCA databases. The data quality of the raw materials in A1 is presented in the table below.

| Materials | Source | Data quality | Year |
|--------------------------------|------------------------|--------------|------|
| HFFR Polyolefin | ecoinvent 3.6 | Database | 2019 |
| Kraft paper - Bleached | ecoinvent 3.6 | Database | 2019 |
| Metal - Copper | Modified ecoinvent 3.6 | Database | 2019 |
| Packaging - Plastic drums | ecoinvent 3.6 | Database | 2019 |
| Plastic - Polyethylene | ecoinvent 3.6 | Database | 2019 |
| Textile - Cotton | ecoinvent 3.6 | Database | 2019 |
| Thermoplastic elastomers (TPE) | ecoinvent 3.6 | Database | 2019 |

System boundaries (X=included, MND=module not declared, MNR=module not relevant)

| Product stage | | | Construction installation stage | | Use stage | | | | | | | End of life stage | | | | Beyond the system boundaries |
|---------------|-----------|---------------|---------------------------------|----------|-----------|-------------|--------|-------------|---------------|------------------------|-----------------------|----------------------------|-----------|------------------|----------|------------------------------------|
| Raw materials | Transport | Manufacturing | Transport | Assembly | Use | Maintenance | Repair | Replacement | Refurbishment | Operational energy use | Operational water use | De-construction demolition | Transport | Waste processing | Disposal | Reuse-Recovery-Recycling-potential |
| A1 | A2 | A3 | A4 | A5 | B1 | B2 | B3 | B4 | B5 | B6 | B7 | C1 | C2 | C3 | C4 | D |
| X | X | X | X | X | X | X | X | X | X | X | X | X | X | X | X | X |

System boundary:

The flowchart below illustrates the system boundaries of the analysis:



Additional technical information:

- Flame retardant: CE Approval, IEC 60332-1-2 - Vertical flame propagation for a single insulated wire or cable
- Halogen free: Yes
- Maximum operating Temperature: 90°C
- Minimum operating Temperature: - 15°C
- Temperatures at installation: min. -15°C to +50°C
- Max. short circuit temperature: 250°C
- Test Voltage: 2 kV AC
- UV resistance: yes
- CPR Performance class: Eca
- EE DoP 1006363 cl. 1 + DoP 1006575 cl. 2 + FI DoP 1001859
- Webpage dk.prysmiangroup.com/dop
- Additional Feature Information: HD 64364-5-52:2011 table B.52.12

LCA: Scenarios and additional technical information

The following information describe the scenarios in the different modules of the EPD.

Module A4 = In A4, an average distance between the factory in Estonia and the market in Denmark is considered.

Modules A5 = 2% product losses during installation are estimated by the company. No energy use for installation has been quantified since this operation is assumed to be done with other products and should be assessed at a construction works level.

Modules B1, B2, B3, B5, and B7 = Company data shows that no significant activities have been reported for use, maintenance, repair, replacement, refurbishment, and water use. This reflects an absence of impacts during the 30 years reference service life of the cable in these modules.

Module B4 = The service life of the building is the same as the service life of the product, no replacement activities are taking place in module B4.

Module B6 = The operational energy use of the cable is calculated based on the methodology described in PEP Ecopassport, Product Specific Rules (PSR) for wires, cables and accessories, reference PSR-0001-ed3-EN-2015 10 16. The following parameters are used to calculate the electricity loss of the cable:

- Reference service life = 30 years (according to appendix 1 of the PSR)
- Number of conductors = 4 units (ground conductor is not transmitting anelectric current and is not included)
- Use rate = 70% percent (according to appendix 1 of the PSR)
- Linear conductor resistivity = 0,00741 Ohm per meter
- Current intensity = 1 Ampere

Module C1 = For both buildings and construction works, cables will be taken out as part of a larger demolition. The energy use for cable removal compared to other heavier materials is assumed to be low. This module can therefore be included with zero impact.

Module C2 = 300 km is added as default average transport to nearest waste treatment facility.

Modules C3 and C4 = Waste treatment of the product follows the default values provided in EN 50693, Product Category Rules for life cycle assessments of electronic and electrical products and systems, table G.4. This table specified how different types of raw materials used in A1 will likely be treated during the end-of-life of the product. Waste treatments in C3 include material recycling and incineration with and without energy recovery and fly ash extraction.

Disposal in C4 consist of landfilling of different waste fractions and of ashes.

Module D = The recyclability of metals and plastics allows the producers a credit for the net scrap that is produced at the end of a product's life. The benefits from recycling of net scrap are described in formula from EN 15804:2012+A2:2019.

Substitution of heat and electricity generated by the incineration with energy recovery of plastic insulation and other parts is also calculated in module D.














| Transport from production place to user (A4) | Capacity utilisation (incl. return) % | Distance (km) | Fuel/Energy Consumption | Unit | Value (Liter/tonne) |
|---|---------------------------------------|---------------|-------------------------|-------|---------------------|
| Ship, Ferry, Sea (km) | 50,0 % | 303 | 0,034 | l/tkm | 10,30 |
| Truck, over 32 tonnes, EURO 5 (km) - Europe | 53,3 % | 1095 | 0,023 | l/tkm | 25,19 |
| Assembly (A5) | | Unit | Value | | |
| Product loss during installation (percentage of cable) | Units/DU | 0,02 | | | |
| Waste, packaging, Polypropylene (PP), to average treatment (kg) - A5, inkl. 85 km transp. | kg | 0,02 | | | |
| Operational energy (B6) | | Unit | Value | | |
| Electricity, Denmark (kWh) | kWh/DU | 5,45 | | | |
| Transport to waste processing (C2) | Capacity utilisation (incl. return) % | Distance (km) | Fuel/Energy Consumption | Unit | Value (Liter/tonne) |
| Truck, 16-32 tonnes, EURO 5 (km) - Europe | 36,7 % | 300 | 0,044 | l/tkm | 13,20 |
| Waste processing (C3) | | Unit | Value | | |
| Copper to recycling (kg) | kg | 0,06 | | | |
| Waste treatment of polyethylene (PE), incineration with energy recovery and fly ash extraction (kg) | kg | 0,01 | | | |
| Waste treatment of plastic mixture, incineration with energy recovery and fly ash extraction (kg) | kg | 0,02 | | | |
| Waste treatment of plastic mixture, incineration with energy recovery and fly ash extraction (kg) | kg | 0,02 | | | |














| Disposal (C4) | Unit | Value | | | |
|---|------|-------|--|--|--|
| Landfilling of yarn and textile waste (kg) | kg | 0,00 | | | |
| Landfilling of copper (kg) | kg | 0,04 | | | |
| Landfilling of ashes from incineration of Polyethylene (PE), process per kg ashes and residues (kg) | kg | 0,00 | | | |
| Landfilling of plastic mixture (kg) | kg | 0,03 | | | |
| Landfilling of graphical paper waste (kg) | kg | 0,00 | | | |
| Landfilling of ashes from incineration of Plastic mixture, process per kg ashes and residues (kg) | kg | 0,00 | | | |
| Landfilling of plastic mixture (kg) | kg | 0,02 | | | |
| Landfilling of ashes from incineration of Plastic mixture, process per kg ashes and residues (kg) | kg | 0,00 | | | |

| Benefits and loads beyond the system boundaries (D) | Unit | Value | | | |
|---|------|-------|--|--|--|
| Substitution of primary copper with net scrap (kg) | kg | 0,03 | | | |
| Substitution of electricity (MJ) | MJ | 0,05 | | | |
| Substitution of thermal energy, district heating (MJ) | MJ | 0,73 | | | |
| Substitution of electricity (MJ) | MJ | 0,03 | | | |
| Substitution of thermal energy, district heating (MJ) | MJ | 0,39 | | | |

LCA: Results

The LCA results are presented below for the declared unit defined on page 2 of the EPD document.

| Environmental impact | | | | | | | | | | |
|---|----------------------------------|------------------------|----------|----------|----------|----------|----------|----|----|----|
| Indicator | | Unit | A1 | A2 | A3 | A4 | A5 | B1 | B2 | B3 |
|  | GWP-total | kg CO ₂ -eq | 6,27E-01 | 4,92E-02 | 5,15E-03 | 2,88E-02 | 1,80E-02 | 0 | 0 | 0 |
|  | GWP-fossil | kg CO ₂ -eq | 6,23E-01 | 4,92E-02 | 5,01E-03 | 2,88E-02 | 1,77E-02 | 0 | 0 | 0 |
|  | GWP-biogenic | kg CO ₂ -eq | 2,03E-03 | 2,03E-05 | 1,32E-04 | 1,07E-05 | 1,99E-04 | 0 | 0 | 0 |
|  | GWP-luluc | kg CO ₂ -eq | 1,83E-03 | 1,74E-05 | 3,16E-06 | 1,08E-05 | 3,67E-05 | 0 | 0 | 0 |
|  | ODP | kg CFC11 -eq | 1,37E-06 | 1,12E-08 | 4,25E-09 | 6,42E-09 | 2,82E-08 | 0 | 0 | 0 |
|  | AP | mol H+ -eq | 3,99E-02 | 1,80E-04 | 2,55E-05 | 3,27E-04 | 8,12E-04 | 0 | 0 | 0 |
|  | EP-FreshWater | kg P -eq | 3,46E-04 | 3,89E-07 | 6,27E-08 | 1,92E-07 | 6,93E-06 | 0 | 0 | 0 |
|  | EP-Marine | kg N -eq | 1,96E-03 | 4,09E-05 | 9,71E-06 | 8,61E-05 | 4,39E-05 | 0 | 0 | 0 |
|  | EP-Terrestrial | mol N -eq | 2,46E-02 | 4,56E-04 | 9,81E-05 | 9,56E-04 | 5,33E-04 | 0 | 0 | 0 |
|  | POCP | kg NMVOC -eq | 7,36E-03 | 1,56E-04 | 2,67E-05 | 2,66E-04 | 1,60E-04 | 0 | 0 | 0 |
|  | ADP-minerals&metals ¹ | kg Sb-eq | 1,17E-04 | 1,28E-06 | 2,73E-08 | 4,16E-07 | 2,82E-06 | 0 | 0 | 0 |
|  | ADP-fossil ¹ | MJ | 1,05E+01 | 7,48E-01 | 9,94E-01 | 4,27E-01 | 2,73E-01 | 0 | 0 | 0 |
|  | WDP ¹ | m ³ | 2,80E+01 | 6,94E-01 | 4,33E-01 | 2,75E-01 | 6,62E-01 | 0 | 0 | 0 |

| Indicator | | Unit | B4 | B5 | B6 | B7 | C1 | C2 | C3 | C4 | D |
|---|----------------------------------|------------------------|----|----|----------|----|----|----------|----------|----------|-----------|
|  | GWP-total | kg CO ₂ -eq | 0 | 0 | 1,84E+00 | 0 | 0 | 1,08E-02 | 1,19E-01 | 9,55E-03 | -6,78E-02 |
|  | GWP-fossil | kg CO ₂ -eq | 0 | 0 | 1,82E+00 | 0 | 0 | 1,08E-02 | 1,15E-01 | 5,90E-03 | -6,72E-02 |
|  | GWP-biogenic | kg CO ₂ -eq | 0 | 0 | 1,89E-02 | 0 | 0 | 4,41E-06 | 4,24E-03 | 3,65E-03 | -2,96E-04 |
|  | GWP-luluc | kg CO ₂ -eq | 0 | 0 | 2,45E-03 | 0 | 0 | 3,78E-06 | 3,89E-07 | 3,50E-07 | -2,88E-04 |
|  | ODP | kg CFC11 -eq | 0 | 0 | 6,20E-08 | 0 | 0 | 2,47E-09 | 2,12E-10 | 3,21E-10 | -4,74E-04 |
|  | AP | mol H+ -eq | 0 | 0 | 7,31E-03 | 0 | 0 | 4,43E-05 | 2,26E-05 | 8,63E-06 | -1,03E-02 |
|  | EP-FreshWater | kg P -eq | 0 | 0 | 1,49E-04 | 0 | 0 | 8,50E-08 | 1,90E-08 | 1,71E-08 | -6,93E-05 |
|  | EP-Marine | kg N -eq | 0 | 0 | 1,23E-03 | 0 | 0 | 1,31E-05 | 1,08E-05 | 1,09E-05 | -4,36E-04 |
|  | EP-Terrestrial | mol N -eq | 0 | 0 | 1,75E-02 | 0 | 0 | 1,45E-04 | 1,12E-04 | 3,43E-05 | -6,69E-03 |
|  | POCP | kg NMVOC -eq | 0 | 0 | 3,74E-03 | 0 | 0 | 4,44E-05 | 2,70E-05 | 1,18E-05 | -1,82E-03 |
|  | ADP-minerals&metals ¹ | kg Sb-eq | 0 | 0 | 1,62E-05 | 0 | 0 | 2,93E-07 | 1,06E-08 | 8,36E-09 | -5,72E-05 |
|  | ADP-fossil ¹ | MJ | 0 | 0 | 2,36E+01 | 0 | 0 | 1,63E-01 | 1,39E-02 | 2,52E-02 | -6,36E-01 |
|  | WDP ¹ | m ³ | 0 | 0 | 3,67E+02 | 0 | 0 | 1,56E-01 | 9,15E-02 | 4,67E-01 | 2,17E+00 |













GWP-total = Global Warming Potential total; GWP-fossil = Global Warming Potential fossil fuels; GWP-biogenic = Global Warming Potential biogenic; GWP-luluc = Global Warming Potential land use and land use change; ODP = Depletion potential of the stratospheric ozone layer; AP = Acidification potential, Accumulated Exceedance; EP-freshwater = Eutrophication potential, fraction of nutrients reaching freshwater end compartment; EP-marine = Eutrophication potential, fraction of nutrients reaching marine end compartment; EP-terrestrial = Eutrophication potential, Accumulated Exceedance; POCP = Formation potential of tropospheric ozone; ADP-minerals&metals = Abiotic depletion potential for non-fossil resources; ADP-fossil = Abiotic depletion for fossil resources potential; WDP = Water (user) deprivation potential, deprivation-weighted water consumption

"Reading example: 9,0 E-03 = 9,0*10⁻³ = 0,009"

*INA Indicator Not Assessed

1. The results of this environmental impact indicator shall be used with care as the uncertainties on these results are high or as there is limited experienced with the indicator

Remarks to environmental impacts











| Additional environmental impact indicators | | | | | | | | | | |
|---|-------------------|----------|----------|----------|----------|----------|----------|----------|----------|-----------|
| Indicator | Unit | A1 | A2 | A3 | A4 | A5 | B1 | B2 | B3 | |
|  PM | Disease incidence | 8,41E-08 | 3,24E-09 | 5,07E-10 | 2,09E-09 | 1,86E-09 | 0 | 0 | 0 | |
|  IRP ² | kgBq U235 -eq | 2,96E-02 | 3,27E-03 | 4,34E-02 | 1,86E-03 | 1,66E-03 | 0 | 0 | 0 | |
|  ETP-fw ¹ | CTUe | 3,25E+02 | 5,52E-01 | 1,98E-01 | 2,98E-01 | 7,06E+00 | 0 | 0 | 0 | |
|  HTP-c ¹ | CTUh | 6,54E-09 | 0,00E+00 | 1,00E-12 | 0,00E+00 | 1,30E-10 | 0 | 0 | 0 | |
|  HTP-nc ¹ | CTUh | 5,42E-07 | 5,90E-10 | 6,10E-11 | 3,03E-10 | 1,09E-08 | 0 | 0 | 0 | |
|  SQP ¹ | dimensionless | 7,44E+00 | 5,57E-01 | 8,73E-02 | 3,96E-01 | 1,87E-01 | 0 | 0 | 0 | |
| Indicator | Unit | B4 | B5 | B6 | B7 | C1 | C2 | C3 | C4 | D |
|  PM | Disease incidence | 0 | 0 | 3,58E-08 | 0 | 0 | 7,79E-10 | 9,70E-11 | 1,60E-10 | -2,36E-08 |
|  IRP ² | kgBq U235 -eq | 0 | 0 | 1,16E-01 | 0 | 0 | 7,14E-04 | 3,34E-05 | 1,49E-04 | -1,27E-03 |
|  ETP-fw ¹ | CTUe | 0 | 0 | 4,21E+01 | 0 | 0 | 1,20E-01 | 1,92E-01 | 2,63E+01 | -9,43E+01 |
|  HTP-c ¹ | CTUh | 0 | 0 | 8,29E-10 | 0 | 0 | 0,00E+00 | 6,00E-12 | 1,00E-12 | -1,33E-09 |
|  HTP-nc ¹ | CTUh | 0 | 0 | 2,75E-08 | 0 | 0 | 1,30E-10 | 2,54E-10 | 3,00E-11 | -1,14E-07 |
|  SQP ¹ | dimensionless | 0 | 0 | 3,88E+01 | 0 | 0 | 1,13E-01 | 2,42E-03 | 6,62E-02 | -1,81E+00 |











PM = Particulate Matter emissions; IRP = Ionizing radiation – human health; ETP-fw = Eco toxicity – freshwater; HTP-c = Human toxicity – cancer effects; HTP-nc = Human toxicity – non cancer effects; SQP = Potential Soil Quality Index (dimensionless)

"Reading example: 9,0 E-03 = 9,0*10⁻³ = 0,009"

*INA Indicator Not Assessed

1. The results of this environmental impact indicator shall be used with care as the uncertainties on these results are high or as there is limited experienced with the indicator
2. This impact category deals mainly with the eventual impact of low dose ionizing radiation on human health of the nuclear fuel cycle. It does not consider effects due to possible nuclear accidents, occupational exposure nor due to radioactive waste disposal in underground facilities. Potential ionizing radiation from the soil, from radon and from some construction materials is also not measured by this indicator.







| Resource use | | | | | | | | | | |
|---|-------|----------------|----------|----------|----------|----------|-----------|----|----|---|
| Indicator | Unit | A1 | A2 | A3 | A4 | A5 | B1 | B2 | B3 | |
|  | PERE | MJ | 1,52E+00 | 1,04E-02 | 1,88E-02 | 4,80E-03 | 3,03E-02 | 0 | 0 | 0 |
|  | PERM | MJ | 4,86E-02 | 0,00E+00 | 0,00E+00 | 0,00E+00 | 1,47E-04 | 0 | 0 | 0 |
|  | PERT | MJ | 1,57E+00 | 1,04E-02 | 1,88E-02 | 4,80E-03 | 3,05E-02 | 0 | 0 | 0 |
|  | PENRE | MJ | 7,50E+00 | 7,48E-01 | 9,97E-01 | 4,27E-01 | 2,11E-01 | 0 | 0 | 0 |
|  | PENRM | MJ | 3,08E+00 | 0,00E+00 | 0,00E+00 | 0,00E+00 | -5,11E-01 | 0 | 0 | 0 |
|  | PENRT | MJ | 1,06E+01 | 7,48E-01 | 9,97E-01 | 4,27E-01 | -3,00E-01 | 0 | 0 | 0 |
|  | SM | kg | 5,58E-02 | 0,00E+00 | 0,00E+00 | 0,00E+00 | 1,14E-03 | 0 | 0 | 0 |
|  | RSF | MJ | 1,55E-02 | 3,72E-04 | 5,34E-04 | 1,62E-04 | 3,65E-04 | 0 | 0 | 0 |
|  | NRSF | MJ | 2,10E-03 | 1,31E-03 | 5,33E-05 | 4,95E-04 | 6,53E-05 | 0 | 0 | 0 |
|  | FW | m ³ | 2,80E-02 | 7,99E-05 | 2,81E-04 | 4,26E-05 | 4,14E-04 | 0 | 0 | 0 |

| Indicator | Unit | B4 | B5 | B6 | B7 | C1 | C2 | C3 | C4 | D | |
|---|-------|----------------|----|----|----------|----|----|----------|-----------|----------|-----------|
|  | PERE | MJ | 0 | 0 | 2,03E+01 | 0 | 0 | 2,30E-03 | 7,27E-04 | 2,52E-03 | -7,92E-01 |
|  | PERM | MJ | 0 | 0 | 0,00E+00 | 0 | 0 | 0,00E+00 | -4,12E-02 | 0,00E+00 | 0,00E+00 |
|  | PERT | MJ | 0 | 0 | 2,03E+01 | 0 | 0 | 2,30E-03 | -4,05E-02 | 2,52E-03 | -7,92E-01 |
|  | PENRE | MJ | 0 | 0 | 2,36E+01 | 0 | 0 | 1,63E-01 | 1,39E-02 | 2,52E-02 | -6,36E-01 |
|  | PENRM | MJ | 0 | 0 | 0,00E+00 | 0 | 0 | 0,00E+00 | -2,42E+00 | 0,00E+00 | 0,00E+00 |
|  | PENRT | MJ | 0 | 0 | 2,36E+01 | 0 | 0 | 1,63E-01 | -2,41E+00 | 2,52E-02 | -6,36E-01 |
|  | SM | kg | 0 | 0 | 0,00E+00 | 0 | 0 | 0,00E+00 | 0,00E+00 | 0,00E+00 | 1,78E-02 |
|  | RSF | MJ | 0 | 0 | 7,63E-01 | 0 | 0 | 8,25E-05 | 1,59E-05 | 5,24E-05 | 1,59E-03 |
|  | NRSF | MJ | 0 | 0 | 4,04E-03 | 0 | 0 | 2,94E-04 | 0,00E+00 | 5,28E-05 | -3,04E-02 |
|  | FW | m ³ | 0 | 0 | 7,53E-02 | 0 | 0 | 1,72E-05 | 1,08E-04 | 3,22E-05 | -2,18E-03 |

PERE = Use of renewable primary energy excluding renewable primary energy resources used as raw materials; PERM = Use of renewable primary energy resources used as raw materials; PERT = Total use of renewable primary energy resources; PENRE = Use of non renewable primary energy excluding non-renewable primary energy resources used as raw materials; PENRM = Use of non renewable primary energy resources used as raw materials; PENRT = Total use of non renewable primary energy resources; SM = Use of secondary materials; RSF = Use of renewable secondary fuels; NRSF = Use of non-renewable secondary fuels; FW = Net use of fresh water

"Reading example: 9,0 E-03 = 9,0*10⁻³ = 0,009"











*INA Indicator Not Assessed

| End of life - Waste | | | | | | | | | | | |
|---|------|----|----------|----------|----------|----------|----------|----------|----------|----------|-----------|
| Indicator | Unit | A1 | A2 | A3 | A4 | A5 | B1 | B2 | B3 | | |
|  | HWD | kg | 5,92E-03 | 3,89E-05 | 2,59E-04 | 2,21E-05 | 1,62E-04 | 0 | 0 | 0 | |
|  | NHWD | kg | 1,67E-01 | 3,93E-02 | 5,78E-03 | 2,93E-02 | 2,29E-02 | 0 | 0 | 0 | |
|  | RWD | kg | 2,59E-05 | 5,10E-06 | 1,68E-05 | 2,93E-06 | 1,14E-06 | 0 | 0 | 0 | |
| Indicator | Unit | B4 | B5 | B6 | B7 | C1 | C2 | C3 | C4 | D | |
|  | HWD | kg | 0 | 0 | 3,12E-03 | 0 | 0 | 8,33E-06 | 0,00E+00 | 1,88E-03 | -6,93E-04 |
|  | NHWD | kg | 0 | 0 | 1,44E-01 | 0 | 0 | 7,80E-03 | 0,00E+00 | 9,18E-02 | -3,15E-02 |
|  | RWD | kg | 0 | 0 | 7,44E-05 | 0 | 0 | 1,11E-06 | 0,00E+00 | 1,69E-07 | -1,10E-06 |

HWD = Hazardous waste disposed; NHWD = Non-hazardous waste disposed; RWD = Radioactive waste disposed

"Reading example: 9,0 E-03 = 9,0*10⁻³ = 0,009"

*INA Indicator Not Assessed

| End of life - Output flow | | | | | | | | | | | |
|---|------|----|----------|----------|----------|----------|----------|----------|----------|----------|-----------|
| Indicator | Unit | A1 | A2 | A3 | A4 | A5 | B1 | B2 | B3 | | |
|  | CRU | kg | 0,00E+00 | 0,00E+00 | 0,00E+00 | 0,00E+00 | 0,00E+00 | 0 | 0 | 0 | |
|  | MFR | kg | 0,00E+00 | 0,00E+00 | 6,86E-03 | 0,00E+00 | 9,58E-03 | 0 | 0 | 0 | |
|  | MER | kg | 0,00E+00 | 0,00E+00 | 1,45E-03 | 0,00E+00 | 9,50E-04 | 0 | 0 | 0 | |
|  | EEE | MJ | 0,00E+00 | 0,00E+00 | 1,30E-03 | 0,00E+00 | 1,51E-03 | 0 | 0 | 0 | |
|  | EET | MJ | 0,00E+00 | 0,00E+00 | 1,97E-02 | 0,00E+00 | 2,29E-02 | 0 | 0 | 0 | |
| Indicator | Unit | B4 | B5 | B6 | B7 | C1 | C2 | C3 | C4 | D | |
|  | CRU | kg | 0 | 0 | 0,00E+00 | 0 | 0 | 0,00E+00 | 0,00E+00 | 0,00E+00 | 0,00E+00 |
|  | MFR | kg | 0 | 0 | 0,00E+00 | 0 | 0 | 0,00E+00 | 6,36E-02 | 4,13E-06 | -6,96E-04 |
|  | MER | kg | 0 | 0 | 0,00E+00 | 0 | 0 | 0,00E+00 | 4,60E-02 | 1,01E-07 | -9,16E-05 |
|  | EEE | MJ | 0 | 0 | 0,00E+00 | 0 | 0 | 0,00E+00 | 7,42E-02 | 6,55E-06 | -2,24E-04 |
|  | EET | MJ | 0 | 0 | 0,00E+00 | 0 | 0 | 0,00E+00 | 1,12E+00 | 9,90E-05 | -3,40E-03 |

CRU = Components for re-use; MFR = Materials for recycling; MER = Materials for energy recovery; EEE = Exported energy electrical; EET = Exported energy thermal

"Reading example: 9,0 E-03 = 9,0*10⁻³ = 0,009"

*INA Indicator Not Assessed

| Biogenic Carbon Content | | |
|---|------|---------------------|
| Indicator | Unit | At the factory gate |
| Biogenic carbon content in product | kg C | 1,35E-03 |
| Biogenic carbon content in accompanying packaging | kg C | 0,00E+00 |

Note: 1 kg biogenic carbon is equivalent to 44/12 kg CO₂

Additional requirements

Greenhouse gas emissions from the use of electricity in the manufacturing phase

National production mix from import, low voltage (production of transmission lines, in addition to direct emissions and losses in grid) of applied electricity for the manufacturing process (A3).

| Electricity mix | Source | Amount | Unit |
|--|---------------|--------|---------------------------|
| Electricity with guarantee of origin, nuclear power, Finland (kWh) | ecoinvent 3.6 | 13,31 | g CO ₂ -eq/kWh |

Dangerous substances

The product contains no substances given by the REACH Candidate list.

Indoor environment

Additional Environmental Information

| Additional environmental impact indicators required in NPCR Part A for construction products | | | | | | | | | | |
|--|------------------------|----------|----------|----------|----------|----------|----------|----------|----------|-----------|
| Indicator | Unit | A1 | A2 | A3 | A4 | A5 | B1 | B2 | B3 | |
| GWPIOBC | kg CO ₂ -eq | 6,30E-01 | 4,92E-02 | 5,13E-03 | 2,88E-02 | 1,79E-02 | 0 | 0 | 0 | |
| Indicator | Unit | B4 | B5 | B6 | B7 | C1 | C2 | C3 | C4 | D |
| GWPIOBC | kg CO ₂ -eq | 0 | 0 | 2,55E+00 | 0 | 0 | 1,08E-02 | 1,15E-01 | 9,78E-03 | -3,55E-02 |

GWPIOBC: Global warming potential calculated according to the principle of instantaneous oxidation. In order to increase the transparency of biogenic carbon contribution to climate impact, the indicator GWP-IOBC is required as it declares climate impacts calculated according to the principle of instantaneous oxidation. GWP-IOBC is also referred to as GWP-GHG in context to Swedish public procurement legislation.

Bibliography

ISO 14025:2010. Environmental labels and declarations - Type III environmental declarations - Principles and procedures. International Organization for Standardization.

ISO 14044:2006. Environmental management - Life cycle assessment - Requirements and guidelines. International Organization for Standardization.

EN 15804:2012+A2:2019. Environmental product declaration - Core rules for the product category of construction products. European Committee for Standardization.

ISO 21930:2017. Sustainability in buildings and civil engineering works - Core rules for environmental product declarations of construction products. International Organization for Standardization.

EN 50693:2019. Product category rules for life cycle assessments of electronic and electrical products and systems. European Committee for Standardization.

Ecoinvent v3, 2019. Allocation, cut-off by classification. Swiss Centre of Life Cycle Inventories.

Iversen et al., (2021). eEPD v2021.09, background information for EPD generator tool system verification, LCA.no. Report number: 07.21. System verification report.

Philis et al., (2022). EPD generator for NPCR 027 part B for electrical wires and cables, background information for EPD generator application and LCA data, LCA.no Report number: 03.22. PCR verification report.

EPD Norway (2022). NPCR Part A: Construction products and services. The Norwegian EPD foundation. Version 2.0 published 24.03.2021.

EPD Norway (2022). NPCR 027 Part B for electrical cables and wires. The Norwegian EPD foundation. Version 2.0 published 01.03.2022.

| | | |
|---|--|--|
|  <small>Global program operator</small> | Program operator and publisher The Norwegian EPD Foundation Post Box 5250 Majorstuen, 0303 Oslo, Norway | Phone: +47 977 22 020 e-mail: post@epd-norge.no web: www.epd-norge.no |
|  | Owner of the declaration: Prysmian Group Danmark A/S Roskildevej 22, 2620 Albertslund, Denmark | Phone: +45 60 39 26 29 e-mail: gustafjonsson@prysmian.com web: |
|  | Author of the Life Cycle Assessment LCA.no AS Dokka 6A, 1671 Kråkerøy, Norway | Phone: +47 916 50 916 e-mail: post@lca.no web: www.lca.no |
|  | Developer of EPD generator LCA.no AS Dokka 6A, 1671 Kråkerøy, Norway | Phone: +47 916 50 916 e-mail: post@lca.no web: www.lca.no |
|  | ECO Platform ECO Portal | web: www.eco-platform.org web: ECO Portal |